

DOE ORDER # None  
96RF03L66

DIST.	LTR	ENC
Bengal, P.		
Benson, C. A.		
Buddy, M. S.		
Burdick, W. J.		
Evans, C. S.		
Findley, M.		
Guinn, L.		
Hopkins, J.		
Jenkins, K.		
Jierree, C.		
Konwinski, G.		
Law, J. E.	X	X
Ledford, J. A.		
Lovseth, T. P.		
Luker, R. S.		
Mast, E. C.		
McAnally, J. L.	X	X
Motyl, K. M.	X	X
Parker, A. M.	X	X
Peterman, B. D.		
Primrose, A. L.		
Power, A.		
Rukavina, F.		
Steffen, D. E.		
Tyson, A. M.		
Zeile, H.		
Dunstan, L.	X	X
Flehweger, R.	X	X
Dunn, R. P.	X	X
Hickman, F.	X	X

RMRS CC (080) X X  
CORRESPONDENCE CONTROL X X

TRAFFIC

## CLASSIFICATION

UCNI  
UNCLASSIFIED X X  
CONFIDENTIAL  
SECRETAUTHORIZED CLASSIFIER  
SIGNATURE

DOCUMENT CLASSIFICATION

REVIEW WAIVER PER

CLASSIFICATION OFFICE

DATE

IN REPLY TO RFP CC NO:

NA

ACTION ITEM STATUS

☐ OPEN ☒ CLOSED  
☐ PARTIAL

LTR APPROVALS:

ORIG &amp; TYPIST INITIALS:

LAD dgl  
RF-46469 (Rev. 04/96)**Rocky Mountain  
Remediation Services, L.L.C.**  
... protecting the environment

Rocky Flats Environmental Technology Site

P.O. Box 464

Golden, Colorado 80402-0464

Phone: (303) 966-2678

Fax: (303) 966-8244

May 22, 1996

David A. Brockman  
Assistant Manager  
Strategy, Integration & Guidance  
DOE, RFFO

Attn: J. Stover

MONTHLY DISCHARGE MONITORING REPORT - NPDES Permit No. CO-0001333 -  
JLM-083-96


Action: Transmit to EPA and CDPHE

The April 1996 Discharge Monitoring Report (DMR), required by the Rocky Flats Plant National Pollutant Discharge Elimination System (NPDES) Permit, is attached.

No spray irrigation occurred from Pond B-3 during the month of April 1996. There was continuous discharge from Pond B-3 (Outfall 001) and the Sewage Treatment Plant (Outfall STP). The Reverse Osmosis Pilot Plant (Outfall 003 and 004) did not operate nor discharge during this reporting period.

During the month of April, Pond A-3 (Outfall 002) pump discharged from April 4, 1996 through April 8, 1996 to below Pond A-4 as part of the construction activities for Pond A-4. Permission to by-pass Pond A-4 was granted to the Site in a letter from the Environmental Protection Agency (EPA) dated March 12, 1996. Additionally, as part of the de-watering activities for the construction project, Pond A-4 (Outfall 007) was discharged on April 23, 1996. Pond B-5 (Outfall 006) discharged continuously from April 25, 1996 through April 30, 1996. No discharges occurred from Pond C-2 (Outfall 007) during the reporting period.

In a letter dated May 10, 1996 to EPA, notification was made of a non-systematic error in recent monitoring at the Sewage Treatment Plant (Outfall STP). Carbonaceous biochemical oxygen demand 5 day test (CBOD5) measurements on samples collected April 30, 1996 and May 1, 1996 have been reported as unquantifiable by the Site's 881 Analytical Laboratories. We are now reporting the result as a possible exceedance of the daily maximum for CBOD5. No result is available for this parameter so the attached forms will show an asterisk (\*) in place of a result. The routine dilution series used in CBOD5 analyses routinely measures an upper detection limit of approximately 25-30 mg/l. All quality assurance and quality control requirements were met for the batch that included this sample, so a laboratory analysis problem does not appear to be a non-systematic error. All other reportable parameters did not indicate abnormal conditions. Attached is a summary of operating parameters measured at the STP during this event. Included in the summary are CBOD5 results from Pond B-3 and the influent of the STP which are typical for these locations. The results from a CBOD5 sample collected at the STP from May 7, 1996 is also unquantifiable. Efforts are underway to evaluate the treatment plant performance, influent waste sources, and other potential causes for an increase in CBOD5 at the STP outfall. A full investigation of the event is being conducted and the results will be reported with the May 1996 DMR. The balance of CBOD5 data available for samples collected after May 7, 1996 show that the STP has returned to operation within permit limitations.

96-RF-03166  
96-RM-ER-0069-DOE

000062114

ADMIN RECORD

BZ-A-000478

David A. Brockman  
May 22, 1996  
96-RF-03166  
Page 2

It is necessary that the Principal Executive Officer sign and date the letter and the DMR forms. Per verbal request of the EPA, forms for those discharge points which were not active are included with the notation of "No Discharge." Additional monitoring data as required by the NPDES Federal Facilities Compliance Agreement is attached on a separate sheet.

The NPDES permit requires that the report be postmarked no later than May 28, 1996, and be sent to the following:

Mr. Don Terrell  
8-ENF-T  
Water Management Division  
U. S. E. P. A., Region VIII  
999 - 18th Street, Suite 500  
Denver, CO 80202-2466

Colorado Department of Public Health and Environment  
Attention: Mr. Robert Shukle  
Monitoring and Enforcement Section  
WQCD - PE - B2  
4300 Cherry Creek Drive South  
Denver, CO 80222-1530

If you have any questions or desire additional information, please contact K. M. Motyl at extension 2172.

I certify that, to the best of my knowledge and that of my staff, the information used to fill out the DMR is complete and accurate.



James L. McAnally, President  
RMRS, L.L.C.

LAD:dql

Orig. and 1 cc - David A. Brockman

Attachments:  
As Stated

cc:  
E. Zika - DOE  
J. Hill - Kaiser-Hill - w/o Attach.  
G. H. Setlock - Kaiser-Hill - " "  
D. A. Ward - SSOC - " "



2

April 1996

Sewage Treatment Plant Effluent Metals Data

Metal, total	Result, ug/l
	<u>04/02/96 and 04/16/96</u>
Antimony	<23.0
Arsenic	<2.0
Beryllium	<1.0
Cadmium	<0.2
Copper	<3.0
Iron	65.4 B
Lead	<10.0
Manganese	24.3
Mercury	<0.2
Nickel	<20.0
Silver	0.20
Zinc	20.6

B - Absolute value of the analyzed result is less than the Contract Required Detection Limit (CRDL).

Sewage Treatment Plant Effluent Volatile Organic Compound Data

VOC	Result, ug/l
	<u>04/02/96</u>
Benzene	<10
Bromoform	<10
Carbon Tetrachloride	<10
Chlorobenzene	<10
Chlorodibromomethane	<10
Chloroethane	<10
Chloroform	2 J
Dichlorobromomethane	<10
1,1-Dichloroethane	<10
1,2-Dichloroethane	<10
1,1-Dichloroethylene	<10
1,2-Dichloropropane	<10
1,3-Dichloropropylene	<10
Ethylbenzene	<10
Methyl bromide	<10
Methyl chloride	<10
Methylene chloride	<10
1,1,2,2-Tetrachloroethane	<10
Tetrachloroethylene	<10
Toluene	<10
1,2-Trans-dichloroethylene	<10
1,1,1-Trichloroethane	<10
1,1,2-Trichloroethane	<10
Trichloroethylene	<10
Vinyl chloride	<10

J - Compound found, but below Practical Quantitation Limit (PQL). Quantitation is estimate.



















NORMALLY MEASURED PERFORMANCE PARAMETERS  
AT THE ONSITE SEWAGE TREATMENT PLANT  
4/15/96 TO 5/19/96

Date	Effluent CBOD5 (mg/l)	Influent CBOD5 (mg/l)	Pond B-3 CBOD5 (mg/l)	pH Effluent (S.U.)	Flow Rate (gal x 1000)	Chlorine Usage (lbs)	Chlorine Concentration (mg/l)	Average Effluent Turbidity (NTU)	Secondary Clarifier Turbidity (NTU)	Average Blower Speed %	Disolved O <sub>2</sub> /Mixed Liquor Aeration Basin (mg/l)	Suspended Solids (mg/l)	Influent Conductivity (ms/cm)
4/15/96				6.9	181	4	1.18	1.492	2.5	28.9	0.4	2777	655
4/16/96	3.1	53.7	1.8	7	156	6	1.31	2.241	7.1	24.7	0.3	2052	658
4/17/96	5.9	50.5		7.1	152	6	1.25	2.11	9.8	27.5	0.6	2941	627
4/18/96				7.1	116	6	1.29	1.676	4.1	32.5	0.2	2764	643
4/19/96				6.7	42	4	1.88	1.314	8.7	29.45	1.05	3426	512
4/20/96				7	66	3	1.42	0.711	5.9	20.1	0.4	4381	533
4/21/96				7	100	5	1.33	0.404	2.2	19.2	0.3	3871	510
4/22/96				7.4	152	7	1.07	0.359	1.5	19	0.2	2969	623
4/23/96	1.8	48.2	2.8	7	186	7	1.21	1.123	6	24.9	0.7	1949	652
4/24/96	4.3	71.5		6.9	164	10	1.01	2.113	7.8	26.4	0.4	2626	663
4/25/96				7	136	7	1.02	1.713	3.8	27	0.2	3417	685
4/26/96				6.9	120	6	1.67	1.915	5	28	0.3	3079	633
4/27/96				6.9	100	6	1.25	1.053	3.8	27.6	0.3	3918	569
4/28/96				6.8	112	6	1.09	0.607	2.2	26	0.2	3245	507
4/29/96				6.8	174	7	1.1	1.064	2.2	26.1	0.2	3195	550
5/1/96	NSE	102.2	19.5	6.7	220	8	1.4	2.34	5.6	31.62	0.36	2654	574
5/2/96	NSE	114.7		6.7	240	9	1.41	2.518	6.4	28.2	0.22	1740	494
5/3/96				6.7	294	9	1.13	2.408	5.9	27.4	0.8	2244	448
5/4/96				6.7	204	6	1.2	1.21	5	27.1	0.41	2771	622
5/5/96				6.8	128	5	0.85	0.54	1.7	26.43	0.53	2873	497
5/6/96				6.8	128	5	1	0.348	1.4	23.83	0.45	2871	498
5/7/96	NSE	128.7	12.7	6.7	228	9	1.11	0.824	1.4	31.13	0.5	2315	613
5/8/96	15.9	210		6.8	196	7	1.45	1.974	5.8	32.87	0.75	2115	723
5/9/96				7.1	242	9	1.37	2.682	2.6	32.42	0.65	2771	622
5/10/96				7.1	176	8	1.43	1.99	5.1	27.1	0.41	3172	532
5/11/96				6.8	212	9	1.03	1.425	4	27.68	0.58	2462	540
5/12/96				6.7	148	7	1.08	1.102	2.6	26.77	0.57	2515	221
5/13/96				7.4	160	6	1.08	0.638	2.5	24.7	0.5	2241	466
5/14/96	3.9	59.9	1.9	7.2	218	8	1.19	0.783	2.8	25.5	0.4	2127	465
5/15/96	4.1	76.3		7.3	232	8	1.29	1.616	4.4	27.87	0.53	1939	890
5/16/96				7.3	186	7	1.34	1.309	3.4	27.8	0.5	2391	594
5/17/96				7.2	152	6	1.48	1.027	2.16	28.6	0.5	2230	580
5/18/96				7.2	116	6	1.11	0.774	2.9	29.18	0.4	2312	949
5/19/96				7.1	104	6	1.17	0.536	2.2	24.9	0.53	2800	515
					120	6	1.25	0.364	3.2	22.4	0.7	2068	462
Period Average	5.6	91.6	7.7	7.0	162	7	1.24	1.32	4.1	26.85	0.46	2718	579
Normal Range				6.0 - 9.0		7 - 10	0.5 - 1.5	1 - 3	2 - 10	18 - 35%	0.1 - 1.5	2000 - 3000	200 - 1500

Note: The bolded and italicized dates are those dates with non-systematic errors for daily values for CBOD5. Pond B-3 CBOD5 results are reported in the monthly DMR, but there is no limitation for this parameter. Influent CBOD5 are not a permit requirement and are provided as additional information.

5/22/96